



NOTE:

- 1) BACKFILL NEXT TO DIKE SHALL BE A FREE DRAINING GRANULAR MATERIAL.
- 2) BACKFILL SHALL BE PLACED, GRADED AND COMPACTED UNIFORMLY & SIMULTANEOUSLY ON BOTH SIDES OF DIKE.
- 3) COMPACTION WITHIN 1.2m OF WALL SHALL BE WITH SMALL PLATE TAMPERS.
- 4) MAINTAIN 150mm FROM WALL WITH ALL COMPACTION EQUIPMENT.
- 5) NO HEAVY EQUIPMENT SHOULD ENCROACH WITHIN 1.2m OF WALL DURING BACKFILL & COMPACTION EFFORTS.

1.829 M HIGH DIKE WALL

REVNO.:	REVISION NOTE:	DATE: D/M/Y	SIGNATURE	CHECKED
MILEPOST MFG. a div. of MILEPOST OILFIELD SERVICES LTD.			DWG.:	
DESIGNED BY:	CHECKED BY:	APPROVED BY - DATE	FILE NAME:	DATE:
	S.D.	M/D/Y	1.829M HT.	
PROJECT LOCATION:			PROJECT: SECTION DETAIL	
				EDITION: 0